



### Datasheet for three-phase Squirrel-Cage-Motors

**Order Number:** 1LE0101-1CB03-4AB4

Client-order-no.:

Order-no.:

Offer-no.:

Remarks:

Item-no.:

Consignment-no.:

Project:



#### Electrical data

Rated motor voltage:	400VD / 690VY
Frequency:	50 Hz
Rated motor power:	5.5 kW
Rated motor speed:	1460 1/min
Maximum Speed:	2700 1/min
Number of poles:	4
No load current:	6.1 A
Rated current:	11.5 A
Starting current:	7.5
Rated motor torque:	35.98 Nm
Torque class:	L
Starting torque:	2.5
Breakdown torque:	3.1
Efficiency class:	IE 2
Efficiency 100% Load:	87.7%
Efficiency 75% Load:	88.2%
Efficiency 50% Load:	86.9%
Power factor 100% Load:	0.79
Motor protection:	3 PTC thermistors for tripping
Terminal box position:	terminal box on top

#### Mechanical data

Noise (Lpfa):	57.00 dB(A)
Moment of inertia:	0.021 kg m <sup>2</sup>
Cantilever force for x0:	2720 N
Cantilever force for xmax:	2170 N
Bearing drive end:	6308 2Z C3
Bearing non-drive end (hor.mount.):	6208 2Z C3
Bearing non-drive end (vert.mount.):	6208 2Z C3
Drain holes:	yes
Regreasing device:	no
Relubrication interval at 40°C:	
Coating:	RAL 7030 stone gray

#### Site conditions

Ambient temperature:	-20.0°C to +40°C
Altitude above sea level:	1000m
Standards and specifications:	IEC

#### General data

Frame size:	132S
Type of construction:	IMB3
Weight in kg (net):	61 kg
Frame material:	Cast iron
Fan cover material:	metal
Degree of protection:	IP 55
Method of cooling:	Self-ventilated (IC 411)
Vibration class:	A (standard)
Insulation:	155(F) / 130(B)
Duty type:	S1 = cont. operation
Direction of rotation:	bidirectional

#### Terminal box

Material of terminal box:	Cast iron
Terminal screw thread:	M4
Max. cable cross-sectional area:	6 mm <sup>2</sup>
Cable diameter from ... to ...:	18 - 25 mm
Cable entry:	M32 x 1.5 + M32 x 1.5
Cable gland:	no

#### Explosion protection

Type of protection:	without (standard)
---------------------	--------------------

#### Special configurations

Technical and ordering data are subject to change. There may be discrepancies between calculated and rating plate values.  
Printed on 2013-02-08