

## Datasheet for three-phase Squirrel-Cage-Motors

**Order Number: 1LE0101-3BA33-4AB4**

Client-order-no.:

Order-no.:

Offer-no.:

Remarks:



Item-no.:

Consignment-no.:

Project:

### Electrical data

Rated motor voltage:	400VD / 690VY
Frequency:	50 Hz
Rated motor power:	250 kW
Rated motor speed:	2980 1/min
Maximum Speed:	3600 1/min
Number of poles:	2
No load current:	46 A
Rated current:	420 A
Starting current:	7.1
Rated motor torque:	801 Nm
Torque class:	J
Starting torque:	2
Breakdown torque:	2.2
Efficiency class:	IE 2
Efficiency 100% Load:	95%
Efficiency 75% Load:	95%
Efficiency 50% Load:	93.0%
Power factor 100% Load:	0.90
Motor protection:	3 PTC thermistors for tripping
Terminal box position:	terminal box on top

### Mechanical data

Noise (Lpfa):	86.00 dB(A)
Moment of inertia:	3 kg m <sup>2</sup>
Cantilever force for x0:	6800 N
Cantilever force for xmax:	6000 N
Bearing drive end:	6319 C3
Bearing non-drive end (hor.mount.):	6319 C3
Bearing non-drive end (vert.mount.):	7319 AC
Drain holes:	yes
Regreasing device:	yes
Relubrication interval at 40°C:	2000 h
Coating:	RAL 7030 stone gray

### Site conditions

Ambient temperature:	-20.0°C to +40°C
Altitude above sea level:	1000m
Standards and specifications:	IEC

### General data

Frame size:	355M
Type of construction:	IMB3
Weight in kg (net):	1650 kg
Frame material:	Cast iron
Fan cover material:	metal
Degree of protection:	IP 55
Method of cooling:	Self-ventilated (IC 411)
Vibration class:	A (standard)
Insulation:	155(F) / 130(B)
Duty type:	S1 = cont. operation
Direction of rotation:	bidirectional

### Terminal box

Material of terminal box:	Cast iron
Terminal screw thread:	M20
Max. cable cross-sectional area:	240 mm <sup>2</sup>
Cable diameter from ... to ...:	44 - 57 mm
Cable entry:	M72 x 2 + M72 x 2
Cable gland:	no

### Explosion protection

Type of protection:	without (standard)
---------------------	--------------------

### Special configurations

Technical and ordering data are subject to change. There may be discrepancies between calculated and rating plate values.

Printed on 2013-02-08